



LICENCIA QUE OTORGA IRAM PARA EL USO DE LA MARCA DE SEGURIDAD DE LA S.I.C. y M.

LICENSE GRANTED BY IRAM FOR THE USE OF THE S.I.C. & M. SAFETY MARK

DC-E-P14-010.1 (C1)

Se deja constancia, por medio de la presente, que el IRAM, Instituto Argentino de Normalización y Certificación, ha otorgado el Sello IRAM de Conformidad con Norma IRAM y la Marca de Seguridad establecida en las Resoluciones de la S.I.C. y M. (Secretaría de Industria, Comercio y Minería) N° 92/98 y 799/99, al producto cuyas características se detallan a continuación:

This document is a written evidence that IRAM, Instituto Argentino de Normalización y Certificación, has granted the IRAM Mark of Conformity with IRAM standards and the Safety Mark established by the Resolutions S.I.C. & M. (Argentine Secretariat of Industry, Commerce and Mining) No. 92/98 and 799/99, to the product with the following characteristics:

EMPRESA BENEFICIARIA (TITULAR) / COMPANY NAME (LICENSE HOLDER):

Prysmian Energía Cables y Sistemas de Argentina S.A.

DOMICILIO LEGAL / OFFICE ADDRESS:

Av. Argentina 6784 (1439), Ciudad Autónoma de Buenos Aires - ARGENTINA

DOMICILIO DE LA(S) PLANTA(S) DE PRODUCCIÓN SUJETA(S) A INSPECCIÓN / ADDRESS(ES) OF THE PRODUCTION PLANT(S) UNDER INSPECTION:

Prysmian Energía Cables y Sistemas de Argentina S.A. / Av. Argentina 6784 (1439), Ciudad Autónoma de Buenos Aires - ARGENTINA

PRODUCTO / PRODUCT:

CABLES PARA ACOMETIDA AEREA CON NEUTRO CONCENTRICO AISLADOS CON POLIETILENO RETICULADO (XLPE) PARA TENSIONES NOMINALES HASTA V0/V= 0,6/1 kV

REFERENCIA DE TIPO O MODELO / TYPE REFERENCE OR MODEL:

RETENAX ANTIHURTO

CARACTERÍSTICAS PRINCIPALES / MAIN CHARACTERISTICS:

Aislación de Polietileno Reticulado y conductores de cobre normalizados. Secciones: 1 x 10 + 10 mm² / 1 x 6 + 6 mm² / 1 x 4 + 4 mm²; Tensión: V0/V= 0,6/1 kV

MARCA / TRADE MARK OR NAME:

"PRYSMIAN"

EN CONFORMIDAD CON LA(S) NORMA(S) / IN CONFORMITY WITH THE STANDARD(S):

IRAM 63001: 2004

El Titular deberá cumplir con las condiciones establecidas en el Reglamento de contratación y uso de las Marcas de Conformidad otorgadas por IRAM según RESOLUCION de la ex S.I.C. y M N° 92/98 y sus Resoluciones y Disposiciones Complementarias (DC/PA 017), que han sido conformados, así como con las resoluciones mencionadas de la S.I.C. y M.

The License Holder shall meet the conditions established by the Regulation for the contracting and use of the Marks of Conformity granted by IRAM under RESOLUTION 92/98 and its Complementary Resolutions and Dispositions, issued by the former Secretariat of Industry, Trade and Mining, which have been signed, together with the above mentioned Resolutions of the S.I.C. & M.

OBSERVACIONES ADICIONALES / ADDITIONAL REMARKS:

Esta Licencia anula y reemplaza a la Licencia N° / This Licence cancels and replaces to Licence N°: DC-E-P14-010.1

Esta Licencia de IRAM ha sido otorgada en base a la Licencia-Certificado-Informe N° / This IRAM License has been granted on the basis of the License-Certificate-Report No. 11804, emitido por / issued by IRAM.

Aprobado por el Comité General de Certificación en su sesión del
Approved by the General Committee for Certification during its meeting held on

2005-12-20 (Acta N° 12-2005)

Ing. Alberto Schiuma
Dirección de Certificación
Certification Direction

